

# Review on Optimal Siting of Electric Vehicle Charging Infrastructure

**Abstract**— Concerns about the need for clean energy and the need to reduce green-house gases have led researchers and engineers to explore adoption of electric vehicle technology. Electric vehicles hold a promising future due to their efficiency, low maintenance cost and zero carbon emission. Unfortunately, due to metric range drawbacks associated with electric vehicles, large scale adoption of electric vehicles still remains relatively low. To solve this issue of range anxiety, optimal placement and sizing methods of electric vehicle infrastructure is essential. This paper presents a review of optimal siting of electric vehicle charging infrastructure. It discusses impacts of electric vehicle charging loads on the distribution network and how large scale electric vehicle penetration would affect the grid. Further, the benefits of electric vehicles on the distribution network as well as the integration of renewable energy resources are presented.

**Keywords**- *Electric Vehicles, Charging Infrastructure, Charging Stations, Optimal Location, renewable energy integration.*

## I. INTRODUCTION

With rising concerns over environmental pollution as well as diminishing oil reserves, research into electric vehicles (EVs) is becoming increasingly popular [1], [2]. EVs also have the added advantage of being easy to maintain, efficient and are cost effective in the long run [1]. Even though during the manufacturing stage of EVs, greenhouse gases are produced, their carbon footprint is much lower than (only about 40%) internal combustion engines (ICEs) [2]-[4]. These reasons make EVs an ideal and realistic alternative to ICE vehicles in the near future. As promising as EVs may seem, they have some major obstacles to overcome such as high initial cost, limited driving range and limited charging infrastructure [1], [2], [5] – [7].

Driver range anxiety is the concern the driver has about running out of power before reaching desired destination [8]. Several factors that affect the range of EVs include temperature, battery charge, terrain, travelling speed, etc. [8]. Limited driving range may likely discourage potential consumers from adopting EVs [9]. In order to tackle such problems (and many more), charging infrastructure is critical to the development and full-scale deployment of EVs. These charging infrastructure include battery charging stations and battery exchange stations.

For EVs to be a viable option, it is important to have an adequate amount of optimally distributed and sized charging stations. Given the electric or transport network of a particular area, optimal placement and sizing of electric vehicle (EV) infrastructure is a multi-objective multi-constraint problem [2]. The most common objectives are maximizing the covered demand or service coverage of EV charging stations and minimizing costs (initial investments, operating costs, maintenance costs) [2], [10]. With respect to the electric grid, significant challenges will arise as a result of increased installation of charging infrastructure. Power loss, voltage profile and system reliability are all factors that must be taken into consideration for successful planning of EV infrastructure [10]. Therefore, optimal siting of EV charge infrastructure becomes essential to the success of EV deployment.

Optimal siting of charging infrastructure has been reported in literature and various methods used [1], [2], [7] – [10]. This paper reviews some of the works previously reported on optimal siting of EV infrastructure.

## II. OPTIMAL SITING OF EV CHARGING INFRASTRUCTURE

The deployment of EV Charging infrastructure is vital to the development of EVs. These charging infrastructure must contend with growing population, change in market trends and other factors that

50 directly affect EV adoption.

51 The EV infrastructure location problem has been widely discussed in literature [1], [2], [8]-[20]. Optimal  
52 siting of charging infrastructure is usually a minimization of the cost, maximizing coverage of charging  
53 stations or a combination of both [2].

54 From the literature reviewed, optimal location of EV charging infrastructure is generally modeled by  
55 considering the transportation network, the electricity distribution network or a hybrid of both [20].

#### 56 *A. Optimal Siting of Charging Infrastructure Using Transportation Network Based Model*

57 Optimal siting of charging infrastructure using transportation network can be further divided into: flow-  
58 based demand model and point-based demand model. In this approach optimal siting is focused on the  
59 transport network alone.

60

##### 61 *i. Flow-based demand model*

62 Flow-demand models try to maximize the vehicle flows along certain paths. Flow Capturing Location  
63 Model (FCLM), Flow Capturing Refueling Model (FCRM) and Maximal Covering Location Model (MCLM)  
64 are path-based approaches for optimal placement of charging station problem. Dimitrios Efthymiou et al.  
65 [2] presented a Genetic Algorithm (GA) approach. Origin destination (OD) data from conventional  
66 vehicles was analyzed with necessary assumptions made. A tool developed in *R* and based on the GA  
67 was used to identify optimal locations for charging stations in the city of Thessaloniki, Greece. The  
68 downside of this method is that the OD data used was from conventional ICE's and not EVs. Also the tool  
69 used was an open source program which may face certain difficulties in the face of computational  
70 complexities. In [21], Ren et al. established a location model to minimize total social cost using GA  
71 to solve the quantity and location of charging stations. The paper details grey decision-making scheme to  
72 calculate quantity and location of charging stations. Unlike earlier studies the paper considered both  
73 quantity and optimal placement of charging stations. Unfortunately, the proposed method is such that  
74 when carrying out index evaluation scoring for a site selection scheme, its result depends on the  
75 subjectivity of the expert. Barış Yıldız et al. [22] proposed an urban model for recharging infrastructure  
76 design problem (RIDP) with stochastic recharging demands, capacitated facilities and deviation  
77 tolerances. These problems were solved by formulating a two stage stochastic programming formulation.  
78 In the first stage, an efficient branch-and-cut algorithm to solve large RIDP instances was obtained. In the  
79 second stage a novel characterization for the feasible solutions of the capacitated flow capturing problem  
80 was derived.

81

##### 82 *ii. Point-based demand model*

83 Points are nodes in transportation networks and are intersections of geographic zones. A point is  
84 modeled as a node-based facility location problem where facilities are placed at nodes based on the  
85 demand at nodes. It has the advantage of low data requirements as only the population and road network  
86 data is necessary.

87 Zheng & Peeta [8] studied the EV routing and optimal charging station location problems. In the optimal  
88 charging station location problem (CSLP) each OD pair was defined within a feasible range and EVs  
89 recharged a limited number of times. This was modeled as a mixed integer mixed commodity problem  
90 which involves many binary variables making it difficult to solve. The authors developed a novel algorithm  
91 based on Benders decomposition which was able to determine the exact solution. Traffic congestion was  
92 not taken into consideration which will likely be a big factor in the shortest path problem. Similarly,  
93 Brandstätter et al. [23] modeled the problem as a time-dependent integer linear program where a  
94 heuristic algorithm was developed to solve it given stochastic demand forecast. Computational studies  
95 carried out on the set of graph grid-based tests analyzed the influence of different parameters on the  
96 overall performance. The study focused on car-sharing systems for optimal CSLP. However the model  
97 assumes that the potential location for charging station is at maximum capacity (i.e. max number of  
98 charging stations) and that cars should be fully charged before a trip. For a faster convergence, Hu et al.

99 [24] proposed a hybrid heuristic algorithm based on Genetic Algorithm (GA) and Binary Particle Swarm  
100 Optimization (BPSO) for the optimal CSLP. The model was derived by forecasting future data of EV  
101 quantities using a unique Nonlinear Autoregressive Neural Network. Results presented show that GA-  
102 BPSO converges faster and reaches better objective value than traditional GA [24]. This is because  
103 BPSO has a better random search ability which gives the GA-BPSO greater diversity, meaning it is less  
104 likely to fall into a local minimum or maximum. Through the hybridization, GA also helps with the slow  
105 convergence of the BPSO.

#### 106 107 *B. Optimal Siting of Charging Infrastructure Using Distribution Network-Based Model*

108 To reduce the adverse effect on the power grid, optimal placement of EV charging infrastructure is  
109 necessary [20]. Some issues like voltage stability, reliability and power losses are addressed while  
110 selecting the optimal locations of EV charging infrastructure with respect to the distribution network [20].  
111 Here only the electric distribution network is considered.

112 Shinde and Swarup [25] presented a locational marginal pricing-based approach to solve the charging  
113 station location problem. The location marginal pricing was calculated at different load buses and based  
114 on that optimal placement was done using a Non-Dominated Sorting Genetic Algorithm (NSGA) and  
115 Multi-Objective Particle Swarm Optimization. When compared to random placement of charging  
116 infrastructure the two optimization techniques saved charging costs [25]. In [10], Mohsenzadeh et al.  
117 presented a Genetic Algorithm solution to the EV infrastructure placing and sizing optimization problem.  
118 The problem was viewed from the perspective of the electric distribution network where changes in  
119 system reliability, power loss, voltage drop, and costs associated with the installation of EV infrastructure  
120 were considered. The EV charging infrastructure, namely parking lots, were considered as distributed  
121 generation sources due to their potential for electricity exchange. The optimal placing and sizing of  
122 parking lots include different levels of charging stations. Using the proposed method, the results show  
123 improvements in the power loss levels, voltage profile, system reliability and costs even though increase  
124 in EVs causes financial and technical challenges in the electric distribution network.

#### 125 126 *C. Optimal Siting of Charging Infrastructure Using Transportation And Distribution Networks-Based 127 Models*

128 A Geographic Information System (GIS) based multi-objective Particle Swarm Optimization (PSO)  
129 technique was used in [26]. PSO was applied to analyze the relationship between upfront and operating  
130 costs and service coverage of the charging stations. Taken into account were charging infrastructure  
131 influence on the loads of power grid as well as the conveniences of the charging station. Here, the GIS  
132 was used to overlay the traffic system and electric power grid together to find EV charging infrastructure  
133 sites. Wang et al. [27] presented a traffic constrained multi-objective planning of EV charging stations  
134 using a novel method. The IEEE 33 bus radial network representing the model electric distribution  
135 network and a 25 node road network were superimposed together. Similarly, the authors in [28]-[31] all  
136 presented optimal allocation of charging stations using a superimposed distribution and road network.  
137 They all either used IEEE's test network or real electric grid in a locality to model the distribution network.

### 138 139 III. IMPACT OF EV CHARGING STATION LOADS ON THE ELECTRIC DISTRIBUTION NETWORK

140  
141 In the future it is expected that there will be high penetration of EVs due to the concerted effort by  
142 governments around the world to reduce greenhouse gases (GHGs) [17]. The transportation sector plays  
143 a key role here as it is the second highest contributor to GHGs [17]. The increase in number of EVs, while  
144 solving some challenges, pose a whole new set of problems especially as it concerns the electric power  
145 grid. An increase in EV charging station loads will lead to rise in peak demand, power loss, voltage  
146 instability, transformer life reduction and power quality problems (due to harmonics, voltage sag and  
147 unbalance) [32] – [50].

148 In addition, EV charging effects on the electric grid depend on the state of charge (SOC) and capacity of  
149 the battery, load profiles of existing feeders and charging modes of the EV. This makes operation and  
150 planning of electric grid more complex with the rise in EV penetration [5]. The EV charging parameters  
151 are usually modeled using stochastic methods to capture the uncertainties.

152

#### 153 *A. Voltage Instability*

154 Voltage instability may cause very low voltage in an electric grid as a result of excess power demand by  
155 the loads, which is beyond the grid's capability. A stable electric distribution network is essential for  
156 steady and reliable power supply. Power outages may be caused as a result of voltage instability due to  
157 excessive power demand. EVs have nonlinear load characteristics and may draw large amounts of  
158 current in a short amount of time [17]. Studies have shown that different load profiles of EVs have an  
159 effect on the voltage stability [17], [32], [33]. This makes studying the effects that EVs have on voltage  
160 stability ever more important. Several methods have been suggested to tackle the issue of instability [34],  
161 [35]. Rajakaruna et al. [34] proposed a voltage control method via tap transformer to reduce instability.  
162 Mitra et al. [35] proposed a wide area control method to dampen out the oscillations in EVs while charging  
163 and discharging to mitigate voltage stability.

164

#### 165 *B. Increase in Peak Demand:*

166 An increase in EV penetration may lead to a corresponding increase in the grid peak demand if there is  
167 uncontrolled charging [36], [37]. In [36] McCarthy et al. determined that a substantial amount of EV loads  
168 must be shifted to off-peak hours for demand to be stable assuming generation is not increased. The  
169 problem of increase in peak demand can be resolved without necessarily increasing generation by using  
170 smart charging and time of use (TOU) tariff plan [38], [39].

171

#### 172 *C. Harmonics:*

173 The nonlinear nature of EVs leads to high frequency components of voltage and current which are integer  
174 multiples of a reference frequency. These high frequency components are undesirable and are known as  
175 harmonics [17]. Harmonics has many negative effects, these include [17], [40]:

- 176 i. Distortion of component waveforms leading to poor power quality.
- 177 ii. It can cause stress in distribution network equipment (e.g. cables and fuses).
- 178 iii. Can lead to current flow in neutral wire.

179 The total amount of voltage or current harmonics can be expressed as total voltage harmonics distortion  
180 (THD<sub>v</sub>) and total current harmonics distortion (THD<sub>i</sub>), given in (1) and (2).

181

$$182 \quad THD_v = \frac{\sqrt{\sum_{h=2}^H V_h^2}}{V_1} \times 100\% \quad (1)$$

184

$$185 \quad THD_i = \frac{\sqrt{\sum_{h=2}^H I_h^2}}{I_1} \times 100\% \quad (2)$$

186

187  
188 Where,  $H$  is the highest harmonic number,  $h$  is the harmonic order number,  $V_h$  is the RMS voltage,  $I_h$  is  
189 the RMS current,  $V_1$  is the RMS value of the fundamental frequency voltage,  $I_1$  is the RMS value of the  
190 fundamental frequency current.

191 Boynuegri et al. [41] proposed various operating modes to eliminate power quality problem in a smart  
 192 grid-compatible system. The results showed a significant improvement in voltage quality and a reduction  
 193 in the total harmonic distortion.

#### 194 *D. Voltage Unbalance*

195 Voltage unbalance or voltage imbalance is a power quality problem that only affects three-phase  
 196 systems. Voltage unbalance happens when the magnitudes of the line or phase voltages are different, the  
 197 phase angles are different (from a balanced system) or both [42]. Voltage unbalance is caused by  
 198 unequal loads in the distribution lines. IEEE defines voltage unbalance as the phase voltage unbalance  
 199 rate (PVUR) given in (3).

200

$$201 \quad \%PVUR = \frac{\text{max voltage deviation from avg.phase voltage}}{\text{avg.phase voltage}} \times 100\% \\ 202 \quad (3)$$

203

204 However the true definition of voltage unbalance (VU) is given as the ratio of negative sequence voltage  
 205 component ( $V_-$ ) to the positive sequence voltage component ( $V_+$ ) shown in (4).

206

$$207 \quad VU = \frac{V_-}{V_+} \times 100\% \\ 208 \quad (4)$$

209

210

211 Shahnia et al. [43] showed that EVs have little impact at the beginning of a low voltage feeder, but have a  
 212 major impact at the end of the feeder. Li et al. [44] also showed that with more than 50% EV penetration  
 213 voltage starts to reduce at the end of the feeder. They also suggested a smart charging plan to mitigate  
 214 the effect of voltage unbalance [44].

215

#### 216 *E. Voltage Sag:*

217 Voltage sag or voltage dip is a reduction in the RMS voltage value for a short duration (half a cycle to one  
 218 minute) of time caused by starting of electrical machines, overload and short circuit. Tie et al. [45] and  
 219 Lee et al. [46] showed the effect of EV penetration on voltage sag limit. Tie et al. [45] showed that up to  
 220 60% EV penetration can be achieved if proper charge control strategies are used. Without any charge  
 221 control strategies, only 10% EV penetration would be acceptable without exceeding the voltage sag limit.

222

#### 223 *F. Power Loss*

224 Power loss is the loss of electrical power supply. Large EV penetration into the electric grid can cause  
 225 huge power losses. Power loss ( $P_{LOSS}$ ) in a distribution network feeder is given in (5).

226

$$227 \quad P_{LOSS} = \sum_n^N I^2 R_n \quad (5)$$

228

229 Where  $N$  is the total number of feeders in a system,  $I$  is the current and  $R_n$  is the resistance across feeder  
 230  $n$ . The extra power loss ( $P_{LE}$ ) caused by EVs can be mathematically expressed as given in (6).

231

$$232 \quad P_{LE} = P_{LEV} - P_{LO} \quad (6)$$

233

234 Where  $P_{LEV}$  is the total power lost when EVs are connected to the electric grid and  $P_{LO}$  is the total power  
 235 lost when the EVs are not connected to the electric grid. Fernandez et al. [47] showed that power loss to  
 236 the electric grid could be as high as 40% if 60% of the EVs in UK were connected at the same time.  
 237 Without coordinated charging schemes the loss could grow even more.

238

239 *G. Overloading of Transformers*

240 Overloading of transformers occur when its voltage or current ratings have been exceeded. Transformer  
241 overloading causes excess heat which affects the insulation of the transformer leading to reduction of  
242 transformer life [48]. Although in areas with low ambient temperature, studies show transformer loading  
243 has little effect on its aging [48].

244 Integration of EVs to the electric grid may increase overloading of transformers. Therefore, proper  
245 transformer selection, network planning and load management are necessary to mitigate the negative  
246 effects of EVs. Some smart metering schemes have been suggested to increase transformer lifespan  
247 [49], [50].

248

249 IV. BENEFITS OF ELECTRIC VEHICLES ON THE ELECTRIC DISTRIBUTION NETWORK

250

251 *A. Vehicle-to-Grid (V2G) Technology*

252 V2G is a service where EVs can provide power back to the electric grid. Power flow can either be  
253 unidirectional or bidirectional. For bidirectional power flow extra equipment are needed to supply power to  
254 the grid from the EV as well as other protection issues related to grid connections. This technology can  
255 increase reliability and potentially reduce peak demand when necessary [51]. EV users can gain  
256 financially from the V2G technology by selling some of their stored power to the grid. Arita et al. [52] and  
257 Sasaki et al. [54] showed the impact of V2G in limiting voltage fluctuations and improving power quality in  
258 the electric grid. In related studies [54]-[56], the authors noted that the V2G technology can provide  
259 voltage support to minimize the use of voltage regulators, reduce distribution line loss and voltage drop.  
260 Constant charging and discharging can have adverse negative effects on the battery life. It is therefore  
261 important that intelligent charging systems are employed to reduce this effect [51].

262 Prasomthong et al. [57] presented optimal placement of V2G enabled charging station in a radial  
263 distribution network and considered the net benefit of the V2G model. Khalkhali et al. [58] proposed an  
264 optimal placement method for a V2G enabled charging station in electric grid. The results showed an  
265 improvement in the voltage profile and reduction in active power loss.

266

267 *B. Smart Grid*

268 Smart Grid technology incorporates communications with decision making to make the electric grid  
269 'intelligent'. This technology paves the way for many solutions to the problems of EV integration into the  
270 electric grid. Reliable power supply, advanced control methods, better integration of renewable energy  
271 resources, V2G and coordinated charging schemes are all advantages of smart grids.

272

273 V. INTEGRATION OF EV CHARGING INFRASTRUCTURE WITH RENEWABLE ENERGY RESOURCES

274

275 Integration of EVs and renewable energy is a promising area due to the need to add distributed  
276 generation to reduce excess stress on the electric grid. Parking lots, rooftops, public buildings are all  
277 potential sites for either Photovoltaic (PV) panel or wind turbine placement. EVs parked under these  
278 structures can conveniently charge using these sources while EV users carry out other activities. Though,  
279 there are other forms of renewable energy resources, this work focuses on wind and solar PV.

280

281 *A. Wind Energy*

282 A number of studies present the impact that EVs have on the electric grids integration with wind energy.  
283 Fernandez et al. [47] showed that V2G technology can increase the penetration of wind energy by up to  
284 59%. Similarly, Turton et al. [59] derived a model that forecasts impact of integration of EVs with a V2G  
285 enabled grid. Their findings show that there is increased renewable energy capacity as a result of the EVs  
286 storage and discharge capability in the V2G scheme. Borba et al. [60] modeled the electric grid in a 20-

287 year span and assumed a huge increase in wind energy generation. The exact size of the hybrid EVs that  
288 could be powered by the excess wind energy was then calculated. They estimated that 1.6 million cars  
289 will be able to be powered during the optimal seasonal conditions (from January to June). Bellekom et al.  
290 in [61] studied the combined and separate effect of EVs and wind energy. The study showed that 4 GW of  
291 wind energy can be added without EV penetration, and 10GW with 1 million EVs. Ekman et al. [62]  
292 discussed the relationship between energy produced and consumed, and EV charging load patterns. EVs  
293 with smart charging capabilities were shown to reduce excess wind generation and could decrease the  
294 backup capacity required. All these studies show that EVs are likely to play a big role in increasing the  
295 wind energy penetration by capturing energy that would have been wasted.

296

### 297 *B. Solar Photovoltaic*

298 EVs and solar PV integration has been widely discussed in literature [63]-[66]. Dallinger and Wietschel  
299 [63] considered both solar PV and wind energy with 50% capacity by 2030 in Germany. The results show  
300 that EVs can absorb about 50% of excess solar PV and wind energy yearly. The author in [64] proposed  
301 installing solar panels on parking lot rooftops. Using New Jersey as a case study, their findings showed  
302 that during summer, given the solar irradiation, module efficiency and parking space, most driving needs  
303 would be met. This was not the same case for winter where average energy production dropped  
304 drastically. The paper however did not mention the economic viability of such systems. Gibson et al. in  
305 [65] and Zhang et al. in [67] discussed the feasibility of EV battery charging using solar PV. Using on-site  
306 generated energy, many losses associated with electric grid were avoided. These losses include,  
307 transmission losses and DC-to-AC conversion losses. The study proves the viability of the method. The  
308 authors in [67] proposed a method in which solar PV is integrated with EVs and heat pumps in Japan.  
309 Their finding showed that with a 30GW solar capacity installed, that would take the overall production  
310 excess to about 10 TWh annually. 5 million EVs and heat pump would absorb all the excess energy. Only  
311 about 30% of excess energy would be absorbed if 1 million EVs and heat pumps were added to the grid.  
312 These studies show that integration of solar energy with EVs would assist in capturing excess energy.

313

314

## VI. CONCLUSION

315 This paper presents a general overview of EV charging infrastructure and impacts of EV on the  
316 distribution grid. Low emission and high efficiency among others are considered as some of the major  
317 benefits of EVs. Despite these benefits, driver anxiety, costs, increase in demand of EVs and by  
318 extension new technical challenges to the electric distribution networks are some of the major impacts.  
319 For this reason it is important for EV charging infrastructure to be optimally placed and sized. Optimal  
320 siting based on the transport network, distribution network or a combination of both were discussed.  
321 Then, the impact of EV charging loads on the electric grid were discussed with various papers proposing  
322 solutions to the challenge. The benefits of EVs to the grid were presented, notably V2G technology was  
323 one of the major benefit that could be derived from this method. It is still clear that V2G technology is an  
324 area for future studies as it makes EVs an asset as opposed to just an ordinary load. Finally, the  
325 integration of solar PV and wind energy has huge potentials for EVs to absorb excess energy. The  
326 integration of these renewable energy resources also helps lift some of the burden from the electric grid.

327

328

329

## VII. REFERENCES

330

- 331 [1] Catalbas, Mehmet Cem, Merve Yildirim, Arif Gulden, and Hasan Kurum. "Estimation of optimal  
332 locations for electric vehicle charging stations." In 2017 IEEE International Conference on  
333 Environment and Electrical Engineering and 2017 IEEE Industrial and Commercial Power  
334 Systems Europe (EEEIC/I&CPS Europe), pp. 1-4. IEEE, 2017.

- 335 [2] Efthymiou, Dimitrios, Katerina Chrysostomou, Maria Morfoulaki, and Georgia Aifantopoulou.  
336 "Electric vehicles charging infrastructure location: a genetic algorithm approach." *European*  
337 *Transport Research Review* 9, no. 2 (2017):
- 338 [3] .Hannan, M.A.; Azidin, F.A.; Mohamed, A. "Hybrid electric vehicles and their challenges: A  
339 review." *Renew. Sustain. Energy Rev.* 2014, 29, 135–150.
- 340 [4] Rezvani, Z.; Jansson, J.; Bodin, J. "Advances in consumer electric vehicle adoption research: A  
341 review and research agenda." *Transp. Res. Part D Transp. Environ.* 2015, 34, 122–136.
- 342 [5] Iqbal, Fahad, Anwar Shahzad Siddiqui, and Tanmoy Deb. "Study of xEV charging infrastructure  
343 and the role of microgrid and smart grid in its development." *Smart Science* 5, no. 2 (2017): 61-  
344 74.
- 345 [6] Axsen J, Kurani KS. "Hybrid, plug-in hybrid, or electric—What do car buyers want?" *Energy*  
346 *Policy.* 2013; 61: 532–543.
- 347 [7] Ehsani M, Gao Y, Gay SE, et al. "Modern electric, hybrid electric, and fuel cell vehicles:  
348 fundamentals, theory, and design." Boca Raton (FL): CRC Press Book; 2009.
- 349 [8] Zheng, Hong, and Srinivas Peeta. "Routing and charging locations for electric vehicles for  
350 intercity trips." *Transportation Planning and Technology* 40, no. 4 (2017): 393-419.
- 351 [9] Ahn Y, Yeo H (2015) "An Analytical Planning Model to Estimate the Optimal Density of Charging  
352 Stations for Electric Vehicles." *PLoS ONE* 10(11): e0141307. doi:10.1371/journal.pone.0141307
- 353 [10] Mohsenzadeh, Amin, Samaneh Pazouki, Shahab Ardalan, and Mahmoud-Reza Haghifam.  
354 "Optimal placing and sizing of parking lots including different levels of charging stations in electric  
355 distribution networks." *International Journal of Ambient Energy* 39, no. 7 (2018): 743-750.
- 356 [11] G. Maggetto and J. Van Mierlo, "Electric and electric hybrid vehicle technology: a survey," IEE  
357 *Seminar Electric, Hybrid and Fuel Cell Vehicles* (Ref. No. 2000/050), Durham, UK, 2000, pp. 1/1-  
358 111. doi: 10.1049/ic:20000261
- 359 [12] Ayob, Afida, Wan Mohd Faizal Wan Mahmood, Azah Mohamed, Mohd Zamri Che Wanik,  
360 MohdFadzil Mohd Siam, Saharuddin Sulaiman, Abu Hanifah Azit, and Mohamed Azrin Mohamed  
361 Ali. "Review on electric vehicle, battery charger, charging station and standards." *Research*  
362 *Journal of Applied Sciences, Engineering and Technology* 7, no. 2 (2014): 364-373.
- 363 [13] Cities, Clean. "Plug-In Electric Vehicle Handbook for Public Charging Station Hosts." US  
364 Department of Energy Publication No. DOE/GO-102012-3275 (2012).
- 365 [14] EV Rater. (2019). List of Electric Vehicles (2019). [online] Available at: <https://evrater.com/evs>  
366 [Accessed 11 May 2019].
- 367 [15] Doug Kettles, "Electric Vehicle Charging Technology Analysis And Standards", Florida Solar  
368 Energy Center FSEC Report Number: FSEC-CR-1996-15, 2015.
- 369 [16] Rahman, Imran, Pandian M. Vasant, Balbir Singh Mahinder Singh, M. Abdullah-Al-Wadud, and  
370 Nadia Adnan. "Review of recent trends in optimization techniques for plug-in hybrid, and electric  
371 vehicle charging infrastructures." *Renewable and Sustainable Energy Reviews* 58 (2016): 1039-  
372 1047.
- 373 [17] Shareef, Hussain, Md Mainul Islam, and Azah Mohamed. "A review of the stage-of-the-art  
374 charging technologies, placement methodologies, and impacts of electric vehicles." *Renewable*  
375 *and Sustainable Energy Reviews* 64 (2016): 403-420.
- 376 [18] Nguyen TD, Li S, Li W, Mi CC. "Feasibility study on bipolar pads for efficient wireless power  
377 chargers." In: *Proceedings of the twenty-ninth annual IEEE applied power electronic conference*  
378 *and exposition (APEC)*; 2014. p. 1676-1682
- 379 [19] Zheng, Yu, Zhao Yang Dong, Yan Xu, Ke Meng, Jun Hua Zhao, and Jing Qiu. "Electric vehicle  
380 battery charging/swap stations in distribution systems: comparison study and optimal planning."  
381 *IEEE Transactions on Power Systems* 29, no. 1 (2014): 221-229
- 382 [20] Deb, Sanchari, Kari Tammi, Karuna Kalita, and Pinakeswar Mahanta. "Review of recent trends in  
383 charging infrastructure planning for electric vehicles." *Wiley Interdisciplinary Reviews: Energy and*



- Environment 7, no. 6 (2018): e306. "Review of recent trends in charging infrastructure planning for electric vehicles". WIREs Energy Environ. 2018.
- [21] Ren, Xianqiang, Huiming Zhang, Ruohan Hu, and Yueming Qiu. "Location of electric vehicle charging stations: A perspective using the grey decision-making model." *Energy* 173 (2019): 548-553.
- [22] Yıldız, Barış, Evren Olcaytu, and Ahmet Şen. "The urban recharging infrastructure design problem with stochastic demands and capacitated charging stations." *Transportation Research Part B: Methodological* 119 (2019): 22-44.
- [23] Brandstätter, Georg, Michael Kahr, and Markus Leitner. "Determining optimal locations for charging stations of electric car-sharing systems under stochastic demand." *Transportation Research Part B: Methodological* 104 (2017): 17-35.
- [24] D. Hu, J. Zhang and Q. Zhang, "Optimization design of electric vehicle charging stations based on the forecasting data with service balance consideration", *Applied Soft Computing Journal* (2018), <https://doi.org/10.1016/j.asoc.2018.07.063>
- [25] Shinde, Priyanka, and K. Shanti Swarup. "A multiobjective approach for optimal allocation of charging station to electric vehicles." In 2016 IEEE Annual India Conference (INDICON), pp. 1-6. IEEE, 2016.
- [26] Yue Zhang, Qi Zhang, Arash Farnoosh, Siyuan Chen, Yan Li, "GIS-Based Multi-Objective Particle Swarm Optimization of Charging Stations for Electric Vehicles," *Energy* (2018), doi: 10.1016/j.energy.2018.12.062
- [27] Wang, G., Xu, Z., Wen, F., & Wong, K. P. "Traffic-constrained multi objective planning of electric-vehicle charging stations." *IEEE Transactions on Power Delivery*, 28(4), 2363–2372, 2013.
- [28] Yao, W., Zhao, J., Wen, F., Dong, Z., Xue, Y., Xu, Y., & Meng, K. "A multi-objective collaborative planning strategy for integrated power distribution and electric vehicle charging systems." *IEEE Transactions on Power Systems*, 29(4), 1811–1821, 2014.
- [29] Leeprechanon, N., Phonrattanasak, P., & Sharma, M. K. "Optimal planning of public fast charging station on residential power distribution system." In *Transportation Electrification Asia-Pacific (ITEC Asia-Pacific)*, 2016 I.E. Conference and Expo (pp. 519–524). Busan, South Korea: IEEE, 2016.
- [30] Islam, M. M., Mohamed, A., & Shareef, H. "Optimal allocation of rapid charging stations for electric vehicles." In *Research and Development (SCoReD)*, 2015 I.E. Student Conference on (pp. 378–383). Kuala Lumpur, Malaysia: IEEE.
- [31] Zhang, C., & Cheng, Y. "Research on joint planning model for EVs charging/swapping facilities." In *Electricity Distribution (CICED)*, 2016 China International Conference on (pp. 1–8). Xi'an, China: IEEE.
- [32] Dharmakeerthi CH, Mithulanathan N, Saha TK. "Impact of electric vehicle fast charging on power system voltage stability." *Int J Electr Power Energy Syst* 2014;57:241–9.
- [33] Xiong J, Member S, Zhang K, Liu X, Member S. Investigating the impact plugin electric vehicle charging on power distribution systems with the integrated modeling and simulation of transportation network. *Transportation Electrification Asia-Pacific (ITEC Asia-Pacific)*, IEEE Conference and Expo, Beijing; 2014. p. 1-5.
- [34] Rajakaruna, S; Shahnia, F; Ghosh, A. *Plug in Electric Vehicles in Smart Grids*, 1st ed.; Springer Science and Business Media Singapore Pte Ltd.: Singapore, 2015.
- [35] Mitra, P.; Venayagamoorthy, G.K. Wide area control for improving stability of a power system with plugin electric vehicles. *IET Gener Transm. Distrib.* 2010, 4, 1151–1163.
- [36] McCarthy D, Wolfs P. The HV system impacts of large scale electric vehicle deployments in a metropolitan area. In: *Proceedings of the 20th Australasian Universities Power Engineering Conference (AUPEC)*, Christchurch; 2010. p. 1–6.

- 432 [37] Putrus GA, Suwanapingkarl P, Johnston D, Bentley EC, Narayana M. Impact of electric vehicles  
433 on power distribution networks. In: Proceedings of the IEEE Vehicle Power and Propulsion  
434 Conference, Dearborn, MI; 2009. p. 827-31.
- 435 [38] Hajimiragha A, Can-izares C, Fowler M, Elkamel E. "Optimal transition to plug- in hybrid electric  
436 vehicles in Ontario, Canada, considering the electricity-grid limitations." IEEE Trans Ind Electron  
437 2010;57:690–701.
- 438 [39] Meyer MK, Scheider K, Pratt R. "Impacts assessment of plug-in hybrid vehicles on electric  
439 utilities and regional U.S. power grids part 1: technical analysis." Richland, WA: Pacific Northwest  
440 National Laboratory; 2007.
- 441 [40] Jiang, C, Torquato, R, Salles, D, Xu, W. "Method to assess the power-quality impact of plug-in  
442 electric vehicles." IEEE Trans. Power Deliv. 2014, 29, 958–965.
- 443 [41] Boynuegri AR, Uzunoglu M, Erdinc O, Gokalp E. "A new perspective in grid connection of electric  
444 vehicles: different operating modes for elimination of energy quality problems." Appl Energy  
445 2014;132:435–51.
- 446 [42] Pillay, P., and M. Manyage. "Definitions of voltage unbalance." IEEE Power Engineering Review  
447 21, no. 5 (2001): 50-51.
- 448 [43] Shahnia F, Ghosh A, Ledwich G, Zare F. "Voltage unbalance sensitivity analysis of plug-in  
449 electric vehicles in distribution networks". In: Proceedings of 21<sup>st</sup> Australasian Universities Power  
450 Engineering Conference (AUPEC), Brisbane, QLD; 2011. p. 1-6
- 451 [44] Li HL, Bai XM, Tan W. "Impacts of plug-in hybrid electric vehicles charging on distribution grid  
452 and smart charging." In: Proceedings of the IEEE POWERCON 2012: International Conference  
453 on Power System Technology; 2012. p.1–5
- 454 [45] Tie, C.H.; Gan, C.K.; Ibrahim, K.A. "The impact of electric vehicle charging on a residential low  
455 voltage distribution network in Malaysia." In Proceedings of the 2014 IEEE Innovative Smart Grid  
456 Technologies— Asia (ISGT Asia), Kuala Lumpur, Malaysia, 20–23 May 2014; pp. 272–277.
- 457 [46] Lee, S.J.; Kim, J.H.; Kim, D.U.; Go, H.S.; Kim, C.H.; Kim, E.S.; Kim, S.K. "Evaluation of voltage  
458 sag and unbalance due to the system connection of electric vehicles on distribution system." J.  
459 Electr. Eng. Technol. 2014, 9,452–460.
- 460 [47] Fernandez, L.P.; San Román, T.G.; Cossent, R.; Domingo, C.M.; Frias, P. "Assessment of the  
461 impact of plugin electric vehicles on distribution networks." IEEE Trans. Power Syst. 2011, 26,  
462 206–213.
- 463 [48] IEEE guide for loading mineral-oil-immersed power transformers up to and including 100 MVA."  
464 ANSI/IEEE Std C57.92-1981.
- 465 [49] Masoum MAS, Moses PS, Deilami S. "Load management in smart grids considering harmonic  
466 distortion and transformer derating." Gaithersburg, MD: IEEE Innovative Smart Grid Technologies  
467 Europe (ISGT Europe); 2010. p. 1–7.
- 468 [50] Qian K, Zhou C, Yuan Y. "Impacts of high penetration level of fully electric vehicles charging  
469 loads on the thermal ageing of power transformers." Int J Electr Power Energy Syst 2015;65:102–  
470 12.
- 471 [51] Mwasilu, F.; Justo, J.J.; Kim, E.K.; Do, T.D.; Jung, J.W. "Electric vehicles and smart grid  
472 interaction: A review on vehicle to grid and renewable energy sources integration." Renew.  
473 Sustain. Energy Rev. 2014, 34, 501–516.
- 474 [52] Arita M, Yokoyama A, Tada Y. "Evaluation of battery system for frequency control in  
475 interconnected power system with a large penetration of wind power generation." In: Proceedings  
476 of the International Conference on Power System Technology (PowerCon); 2006. p. 1-7.
- 477 [53] Sasaki T, Kadoya T, Enomoto K. "Study on load frequency control using redox flow batteries."  
478 IEEE Trans Power Syst 2004;19(1):660–7.

- 479 [54] Ohtaka T, Uchida A, Iwamoto S. "A voltage control strategy with NAS battery systems  
480 considering interconnection of distributed generations." In: Proceedings of the International  
481 Conference on Power System Technology (PowerCon); 2004. p. 226–31.
- 482 [55] Wade N, Taylor P, Lang P, Svensson J. "Energy storage for power flow management and  
483 voltage control on an 11 kV UK distribution network." In: Proceedings of the 20th International  
484 Conference and Exhibition on Electricity Distribution; 2009. p. 1-4.
- 485 [56] Ehsani M, Milad Falahi M, Lotfifard S. "Vehicle to grid services: potential and applications."  
486 *Energies* 2012;5(10):4076–90.
- 487 [57] Prasomthong, J., Ongsakul, W., & Meyer, J. "Optimal placement of vehicle-to-grid charging  
488 station in distribution system using particle swarm optimization with time varying acceleration  
489 coefficient." In *Green Energy for Sustainable Development (ICUE)*, 2014 International Conference  
490 and Utility Exhibition on (pp. 1–8). Pattaya, Thailand: IEEE.
- 491 [58] Khalkhali, K., Abapour, S., Moghaddas-Tafreshi, S. M., & Abapour, M. "Application of data  
492 envelopment analysis theorem in plug-in hybrid electric vehicle charging station planning." *IET*  
493 *Generation, Transmission & Distribution* 2015, 9(7), 666–676
- 494 [59] Turton H, Moura F. "Vehicle-to-grid systems for sustainable development: an integrated energy  
495 analysis." *Technological Forecasting & Social Change* 2008;75:1091–108.
- 496 [60] Borba B, Szklo A, Schaeffer R. "Plug-in hybrid electric vehicles as a way to maximize the  
497 integration of variable renewable energy in power systems: the case of wind generation in  
498 northeastern Brazil." *Energy* 2012;37:469–81.
- 499 [61] Bellekom S, Benders R, Pelgrom S, Moll H. "Electric cars and wind energy: two " problems, one  
500 solution? A study to combine wind energy and electric cars in 2020 in The Netherlands." *Energy*  
501 2012;45(1):859–66.
- 502 [62] Ekman C. "On the synergy between large electric vehicle fleet and high wind penetration—an  
503 analysis of the Danish case." *Renewable Energy* 2011;36:546–53.
- 504 [63] Dallinger D, Wietschel M. "Grid integration of intermittent renewable energy sources using price-  
505 responsive plug-in electric vehicles." *Renewable Sustainable Energy Reviews* 2012;16:3370–82
- 506 [64] Birnie D. "Solar-to-vehicle (S2V) systems for powering commuters of the future." *Journal of*  
507 *Power Sources* 2009;186:539–42.
- 508 [65] Gibson T, Kelly N. "Solar photovoltaic charging of lithium-ion batteries." *Journal of Power*  
509 *Sources* 2010;195:3928–32.
- 510 [66] Kelly N, Gibson T. "Solar photovoltaic charging of high voltage nickel metal hydride batteries  
511 using DC power conversion." *Journal of Power Sources* 2011;196:10430–41.
- 512 [67] Zhang Q, Tezuka T, Ishihara K, Mclellan B. "Integration of PV power into future low-carbon smart  
513 electricity systems with EV and HP in Kansai Area, Japan." *Renewable Energy* 2012;44:99–108.  
514  
515